



PROPANE SAFETY INSPECTION



Account # 3494 Name JAMES & DOREEN LAFLEUR Address [90904] 5153 GRISWALD STREET City MIDDLEPORT
State NY Zip 14105 Phone (716) 983-9797 Date of Inspection 08/14/2026 Branch/Location Work Order #

Equipment Type	Water Heater	Furnace	Clothes Dryer	Range	
Manufacturer	Rheem	York	Whirlpool	Frigidaire	
Year Manufactured	2026	NV	NV	NV	
Model #	XP40S12HE36U0	TM9T080B12MP11B	LGQ8858HQ1	GCFG3060BFA	
Serial #	Q142603577	W1L5081736	MK046787	VF41331987	
Fuel	Propane	Propane	Propane	Propane	
BTUs (Maximum Input)	36,000	80,000	22,000	18,000	
Manual Shutoff Valve	OK	OK	OK	OK	
Sediment Trap	OK	OK	N/A	N/A	
Burner(s) Condition	OK	OK	N/A	OK	
Combustion Chamber Condition	OK	OK	N/A	OK	
Control/Pilot Safety System	OK Electronic	OK Electronic	OK Electronic	OK Electronic	
Venting System	OK	OK	OK	OK	
Combustion Air	OK	OK	OK	OK	
Taken Out of Svc or Operation (Tag #)	No	No	No	No	

CONTAINER CHECK	Serial #	Cust. Own	Container Type		Size	Tank %	Manufacturer	Mfr. Date	DOT		Container			Relief Valve			Fittings Leak Test
			ASME/ DOT	AG/UG/AGUG					Last Requal Date	Type	Found.	Loc.	Cond.	Cond.	Date	Cap	
	702379	N	ASME	AG	500 wg	54	Trinity	1990	N/A		OK	OK	OK	OK	NV	OK	OK

PIPING		Material	Size	Protection	REGULATOR(S)		Mfr.	Model #	Date Code	Cond.	Vent Position	Protection
	1st Stg	CT (Copper Tubing)	3/8	OK		2nd Stg	Fisher	H522-CFF	1992	OK	OK	OK
	2nd Stg	BP (Black Iron Pipe)	3/4	OK		1st Stg	Fisher	R122H-AAJ	2012	OK	OK	OK
	2nd Stg	BP (Black Iron Pipe)	1/2	OK								

CSST TRACKING (IF APPLICABLE)	Bonded	☐ Yes ☐ No ☐ Unknown	Jurisdictional Acct.	☐ Y ☒ N ☐ Unknown	Gas Lines Capped	☐ Y ☒ N/A	Heat Pump	☐ Y ☒ N
-------------------------------	--------	---	----------------------	---	------------------	--	-----------	--

System Type	System Leak Check ☒ Entire System					Pressure Test				System Operation Tests			
	Initial/Start Pressure	End Pressure	Start Time	End Time		Start Pressure	End Pressure	Start Time	End Time	Flow Pressure Test	Lock-Up Pressure Test		
Integral	☐ WC ☐ PSI	☐ WC ☐ PSI				50	PSI	50	PSI	10:29	10:39	☐ WC ☐ PSI	☐ WC ☐ PSI
	☐ WC ☐ PSI	☐ WC ☐ PSI					PSI		PSI			☐ WC ☐ PSI	☐ WC ☐ PSI
	☐ WC ☐ PSI	☐ WC ☐ PSI					PSI		PSI			☐ WC ☐ PSI	☐ WC ☐ PSI
	☐ WC ☐ PSI	☐ WC ☐ PSI					PSI		PSI			☐ WC ☐ PSI	☐ WC ☐ PSI

Performed Sniff Test	☒ Y ☐ N	Comments
----------------------	--	----------

Disclaimer: This inspection covers gas equipment and appliances visible and readily accessible to the service technician and represents the conditions existing on the date of inspection. It does not cover latent or manufacturing defects, the internal workings of sealed equipment or structural components, and cannot be construed to cover future or unforeseen happenings.

I, ☒ Property Owner ☐ Tenant ☐ Authorized Representative, **acknowledge** that the individual performing the propane safety review informed me of the procedure and the outcome of the review; what was covered by the review and what was not covered; what repairs and/or alterations, if any, were made to the gas system or appliances; and options available for making recommended changes to my gas system. **I further acknowledge** that:

- I have informed the individual performing the propane safety review of all gas-burning appliances and gas lines on my property.
- I have been told what to do if I smell a gas odor or otherwise suspect a gas leak and have been shown how to turn the gas off at the tank.
- I have smelled the propane gas and can detect its odor.
- I have been told that the odorant giving propane its distinctive smell can fade or diminish in intensity.

In addition, I have been told that certain physical limitations or conditions might prevent me from smelling a gas leak.

- I have received customer safety information and been told to read it and share it with all family members.
- I am satisfied with the service work performed.
- I have been advised to install one or more gas and carbon monoxide detectors listed by Underwriters Laboratories (UL) as an additional measure of safety.

I have been provided the following additional safety materials:

- ☐ Propane Safety Booklet (PRC-005606 or PRC-101063)
- ☐ Important Propane Safety Information Brochure (PRC-003121 or PRC-101062)
- ☐ Carbon Monoxide Brochure (PRC-000075)

Adam Clyde
Service Technician Name - Print

Service Technician Signature

08/14/2026
Date

JAMES & DOREEN LAFLEUR
Customer Name - Print

Customer Signature

08/14/2026
Date