

Snyder Fuel Service Inc.

LP Gas Consumer Installation Record

113909-1

Name: Caroline Clayton Installation/Inspection Date: 8-11-26
 Street: Millwood hill City: Ohio State: N.Y. Phone: 315-826-7644

	Furnace	Kitchen Range	Water Heater	Clothes Dryer	Com water
Manufacturer	<u>Thermopile</u>	<u>G.E.</u>			<u>General</u>
Serial/Model Number	<u>CMA4-75D36W</u>				
BTU Rating	<u>75,000</u>				

System or equipment "Red Tagged" due to condition or because subject to recall? ☐ Yes ☒ No
 If yes, explain/identify _____

Is each vented type of appliance vented to the outside air? ☒ Yes ☐ No

Any unvented space heaters installed in bedrooms? ☐ Yes ☒ No

If yes, is each heater equipped with an oxygen depletion safety shutoff system? ☐ Yes ☒ No

Size of tank(s) 500 Tank(s) located 10 feet from closest building

Tank(s) mounted on substantial, non-combustible base? ☒ Yes ☐ No

Any sources of ignition within 10 feet (5 feet for cylinders in exchange service)? ☐ Yes ☒ No

	Starting Pressure	Ending Pressure	Time Held (Minutes)	Leak Free? (Yes or No)
Leak Check	<u>9"</u>	<u>9"</u>	<u>10 min</u>	☒ Yes ☐ No

Service Line is: Iron Pipe 3/4 x 1/2 Copper Tubing _____ Plastic _____ Other _____

Piping or tubing is buried and/or protected from damage? ☒ Yes ☐ No

Does the service line enter the structure above ground? ☒ Yes ☐ No

If no, is it sealed or installed in gas tight conduit? ☐ Yes ☒ No

Any unused gas piping outlets indoors? ☐ Yes ☒ No

If yes, is each unused gas piping outlet fitted with a gas tight threaded plug or cap? ☐ Yes ☒ No

First Stage or Twin Stage Regulator Date Code _____ Second Stage Regulator Date Code _____

All regulators located outdoors are installed or protected so operation will not be affected by the elements (for example, freezing rain, sleet, snow, ice, mud, or debris)? ☒ Yes ☐ No

All regulators properly secured? ☒ Yes ☐ No

Second stage regulator located outdoors? ☒ Yes ☐ No

If not, is the vent outlet piped out of doors? ☒ Yes ☐ No

Is regulator vent discharge located at least 3 feet horizontally away from any building opening below the level of the discharge? ☒ Yes ☐ No

By signing I, Caroline Clayton Customer's Name acknowledge:

- I understand how to turn off my supply of gas in case of emergency.
- I have smelled propane and can detect its odor.
- I have received consumer safety information and an odor sniff sample.
- I have been advised to install a combustible gas detector.
- Any deficiencies and/or corrections necessary have been clearly explained to me.

Customer Signature: [Signature] Date: 8-11-26

Service Technician Signature: [Signature] Date: 8-11-26

This inspection is expressly limited to LP gas piping and equipment visible and accessible to the service technician and reflects the conditions existing at the time of the inspection.